



BHAWANIPUR GLOBAL CAMPUS

(An Autonomous Institution)

DECLARATION

TO WHOMSOEVER IT MAY CONCERN

This is to declare that at present, Bhawanipur Global Campus (An Autonomous College) holds a valid Fire Safety Certificate bearing Memo No: FSR/IND/WB/FES/20192020/51508 dated 05.09.2025 issued in its previous name i.e. NSHM Knowledge Campus, Kolkata-Group of Institution. The said certificate is valid for 03 (three) years and has to be renewed every three (03) years from the date of issue of this letter.

Upon expiry of the existing Fire and Safety Certificate, the College shall apply for and obtain a fresh Fire and Safety Certificate in its current name i.e. **Bhawanipur Global Campus (An Autonomous College)** from the competent authority, in accordance with applicable rules and regulations.

This declaration is issued for record and compliance purposes.

Enclosed herewith:

- Fire Safety Certificate dated 05.09.2025 issued by the Office of the Director General, West Bengal Fire & Emergency Services, Government of West Bengal.

Dr. Soumendra Nath Bandyopadhyay
Principal



A Unit of The Bhawanipur Gujarati Education Society

© 60, B.L. Saha Road, Kolkata 700 053 ☎ 033 6521 5300 / 2403 2300 ✉ kolkata@nshm.com

© Regd. Office: 5, Lala Lajpat Rai Sarani, Kolkata - 700 020 (India)

॥ विद्याऽमृतमस्तुते ॥



सत्यमेव जयते

Government of West Bengal
Office of the Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata – 16

Memo No.:FSR/IND/WB/FES/20192020/51508

Date : 05-09-2025

From :
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To :
NSHM KNOWLEDGE CAMPUS KOLKATA, a division of H. C. G. Charitable Trust
60, B. L. Saha Road, P.S. Behala, Kolkata 700 053.

Sub : Fire Safety Certificate for the occupancy of an Existing Construction comprising of 2 nos. blocks i.e. G+IV storied shown as block- 1 & another is B+G+VI storied shown as Block-2 under group of Educational Building in the name & style of "NSHM KNOWLEDGE CAMPUS KOLKATA", a division of H.C.G. Charitable Trust at premises no. 60 (124), B.L. Saha Road, P.S- Behala, Kolkata 700053.

No.:FSR/IND/WB/FES/20192020/51508

This is in reference to your AIN 211892506300007687 dated 25-Jul-2025 regarding Fire Safety Certificate for the occupancy of an Existing Construction comprising of 2 nos. blocks i.e. G+IV storied shown as block- 1 & another is B+G+VI storied shown as Block-2 under group of Educational Building in the name & style of "NSHM KNOWLEDGE CAMPUS KOLKATA", a division of H.C.G. Charitable Trust at premises no. 60 (124), B.L. Saha Road, P.S- Behala, Kolkata 700053..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

- 1.All the Fire Safety measures provided in the building must be kept in good working condition all the time to ensure fire & life safety of the buildings.
- 2.Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
- 3.Entry / Exit in the premises, rooms and floors marked in the plan drawings, use of floor shall not be changed, from the approved plan drawings, without prior approval of this Directorate.



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300007687

- 4.The Interior finish decoration of buildings shall be made with low flame spread material confirming to the I.S. Specification.
- 5.To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the buildings shall be strictly maintained.
- 6.Existing Electrical wiring of the whole buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
- 7.If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
- 8.A Fire control room including a closed-circuit TV system shall have to be maintained which observe all the floors of the buildings.
- 9.The notice of Fire Fighting and Evacuation from the buildings shall be prepared and displayed at all vulnerable places of the buildings.
- 10.A crew of trained Fireman under experienced officer shall be maintained round the clock for fire safety of the buildings.
- 11.The employees and security staff shall be conversant with installed firefighting equipments of the buildings and to operate in the event of fire and testing.
- 12.Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants & employees of the buildings.
- 13.Electrical Control Panel shall be protected with automatic CO2 or DCP Fire extinguishers confirming I.S. specifications.
- 14.Proper Maintenance of all lifts to be done.
- 15.Fire License shall have to be renewed for storing and/or processing of LPG for Gas Bank. LPG Bank shall be protected as per relevant IS Specification.
- 16.Basement shall be used as approved nature of occupancy; storage of inflammable articles shall not be permitted.
- 17.First Aid Fire Fighting system shall be provided as per I.S. specifications.
- 18.All the Fire Pumps are kept in auto mode and connected to DG.
- 19.All the vertical and horizontal ducts including all electrical ducts to be sealed by approved fire resistance materials.
- 20.Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the buildings to keep them in perfectly good working condition at all the times.
- 21.The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
- 22.FCD shall have to be sealed with rubber sealing properly in order to prevent percolation of smoke.
- 23.Periodical flashing of water in the Hydrants pipe line shall be made to maintain the efficient working performance of abovementioned system.
- 24.This Fire Safety Certificate is valid for 03 (three) years and has to be renewed every three (03) years from the date of issue of this letter.
- 25.A certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

Valid Upto : 03-Sep-2028



Validity unknown

Digitally Signed
Name: SHYAM CHANDRA MONDAL
Date: 05-Sep-2025 15:58:25
Reason: D-Sign
Location: E-Dist 2.0

Director

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300007687